



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 289-07-M

Manufacturer: Ultraflex Systems Inc., 1578 Sussex Turnpike,
Building #4, Randolph, N.J. 07869

Trade Name(s): BIOflex

Product: PVC-coated vinyl material

Pertinent Code Section(s): 27-499, 27-501, 27-506, 27-507, TPPN #11/99

Prescribed Test(s): RS 7-3 (NFPA 701-Test Method 2)

Laboratory: The Govmark Organization

Test Report(s): Report Nos. 2-68402-0, 2-68402-1, 2-68402-2-RP,
issued June 25, 2007.

Description: PVC-coated vinyl material for digital and screen printing for in- or outdoor signs, banners and billboards. Material weighs 13.2 ozs. per square yard.

Terms and Conditions: The above-described material is accepted with the following conditions:

1. The acceptance of this material is limited to flame resistance.
2. Structural and other requirements shall be in accordance with pertinent Building Code provisions and Technical Policy and Procedure Notice #11/99.

3. All installations, uses and locations shall be in accordance with the New York City Building Code, specifically with Section 27-499 and 27-501, and the Zoning Resolution.
4. All shipments and deliveries of such material shall be provided with a label, suitably placed, certifying that the material shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance September 19, 2007

Examined By Simon DerPheden