

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 78-02-M

Report of Material and Equipment Acceptance Division

Manufacturer – Ultraflex System, Inc., 385 Franklin Avenue, Rockaway, New Jersey 07866.

Trade Name – **UltraBlackout Banner Pro 15 oz.**

Product - PVC coated fabric for flex sign.

Pertinent Code Section(s) -27-499, 27-501, 27-506, 27-507, and TPPN #11/99.

Prescribed Test(s) - RS 7-3 [NFPA 701(Test Method 2)].

Laboratory - Govmark Organization Inc.

Test Report(s) - Test Report #2-38690-0,1,2 dated January 15, 2002.

Description –UltraBlackout Banner Pro material for use as flex sign, is a polyester fabric coated with PVC vinyl, 16 mil, 15 oz./yd² (7'2" and 10'6" widths). It is used for large hanging banners and signs. It is suited for double sided computer inkjet printed signs and banners.

Recommendation - That the above material be accepted as meeting the flame resistance requirements of Section 27-506 and 27-507 of the Building Code, for use on flex signs. The acceptance of this material is limited to flame resistance only. Structural and other requirements shall be in accordance with pertinent Building Code provisions and Technical Policy and Procedure Notice #11/99. All installations, uses and locations shall be in accordance with the New York City Building Code, specifically with Section 27-499 and 27-501, and the Zoning Resolution. All shipments and deliveries of such materials shall, in addition, be accompanied by a tag, certifying that the materials shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance April 25/2002
Examined By S. Deepkudam