

Intertek  
UBC 26-6  
TEST RESULTS

**Client:** Ultraflex Systems Inc.

**Project No.:** 3181043SAT-003B

**Date:** 6/29/2009

**SPECIMEN I.D.** Ultravision Window Perf

Flash-Ignition Temperature: 390 °C ( 734 °F) Flaming

Spontaneous-Ignition Temperature: 420 °C ( 788 °F) Flaming