

Intertek  
UBC 26-7  
TEST RESULTS

**Client:** Ultraflex Systems  
**Project No.:** 3177352SAT-003B

**Date:** 4/30/09

**SPECIMEN I.D.:** UltraMesh Supreme

***Classification Criteria***

Plastic materials that have a burning extent of 25 mm or less are classified as CC1.  
Plastic materials that have a burning rate of 64 mm/minute or less are classified as CC2.

Specimen	Total Time t (sec.)	Average Extent of Burning (mm)	Average Time of Burning t-30 (sec.)
1	32	22	2
2	31	17	1
3	31	14	1
4	31	13	1
5	30	14	0
6	31	20	1
7	32	22	2
8	31	16	1
9	33	22	3
10	31	12	1
<b>Average</b>	31	17	1

This material met the CC1 classification.