

**CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

**Richard C. Visconti, R.A., Acting Commissioner  
MEA 67-00-M  
Report of Material and Equipment Acceptance Division**

**Manufacturer - Ultraflex System, Inc., 385 Franklin Avenue, Rockaway, New Jersey 07866.**

**Trade Name - Eclipse.**

**Product - PVC coated fabric for flex sign.**

**Pertinent Code Section(s) -27-499, 27-501, 27-506, 27-507, and TPPN #11/99.**

**Prescribed Test(s) - RS 7-3 [NFPA 701 (Test Method 2)].**

**Laboratory - Magil Laboratory.**

**Test Report(s) - Test Report #QLL 18030, dated March 1, 2000.**

**Description - The material is an extruded flame retardant PVC with the base fabric being a 2.23 oz. polyester 9x9 with a 1000 denier. The membrane when extruded has 5.86 oz. of flame retardant PVC laminated to the face and 3.91 oz. of flame retardant PVC laminated to the back. The intended application is for billboard applications.**

**Recommendation - That the above material be accepted as meeting the flame resistance requirements of Section 27-506 and 27-507 of the Building Code, for use on flex signs. The acceptance of this material is limited to flame resistance only. Structural and other requirements shall be in accordance with pertinent Building Code provisions and Technical Policy and Procedure Notice #11/99. All installations, uses and locations shall be in accordance with the New York City Building Code, specifically with Section 27-499 and 27-501, and the Zoning Resolution. All shipments and deliveries of such materials shall, in addition, be accompanied by a tag, certifying that the materials shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.**

**Final Acceptance**           MAY 25 2000          

**Examined By**           S Derphudam