



## FLAME RETARDANT

### Fabric Registration

**LICENSE NUMBER: F-078001**

**ULTRABLOCKOUT BANNER PRO**

**Product Marketed by:**

**ULTRAFLEX SYSTEMS**

1578 SUSSEX TPK., BLDG. 4  
RANDOLPH, NJ, 07869

**Issue Date :** 06/23/2022

**Expiration Date :** 06/30/2023

This product meets the minimum requirements of flame resistance established by the California State Fire Marshal for products identified in Section 13115, California Health and Safety Code.

The scope of the approved use of this product is provided in the current edition of the  
CALIFORNIA APPROVED LIST OF FLAME RETARDANT CHEMICALS AND  
FABRICS, GENERAL AND LIMITED APPLICATIONS CONCERNS published by the  
California State Fire Marshal.

---

Issued By Vikkie Franklin  
Fire Engineering License Manager  
Fire Engineering & Investigations Division

---

Reviewed and Approved By Patricia Setter  
Deputy State Fire Marshal III  
Fire Engineering & Investigations Division

#### OFFICE OF THE STATE FIRE MARSHAL

Please visit [calfire.govmotus.org](http://calfire.govmotus.org) for more information on Licensing and Permitting with CAL FIRE



Received: 04/06/2009 Completed: 04/08/2009 Letter: A rb P.O.#: Test Report #: 2-78069-0-

Client's Identification UltraBlockout Banner Pro Double-Sided Blockout Banner Material For Two-Sided Printing.

Tested For: **Jaime L. Giannantonio**

Ultraflex Systems Inc.  
1578 Sussex Tpk., Bldg. #4  
Randolph, NJ 07869

Key Test: CA 1237 Sm

105

Tel: 1-(973)-627-8608

Ext: 124

Fax: 1-(973)-627-8506

PC: 1H /jd

TEST PERFORMED: California Fire Marshal Title 19: Section 1237 (Proposed Revision 8/9/93) Fire Resistance; Small Scale Test - EXTERIOR MATERIALS QUALIFICATION

RESULTS REPORTED: ☒ Initially  
☐ After 72 hours water leaching  
☐ After 100 hours weathering

RESULTS:	Specimen #	Afterflame (seconds)	Afterglow (seconds)	Char Length (inches)
Warp:	1	0	0	3.8
	2	0	0	4.5
	3	0	0	3.2
	4	0	0	3.6
	5	0	0	4.1
	Avg:	0		
Fill:	6	0	0	3.2
	7	0	0	3.3
	8	0	0	4.1
	9	0	0	3.5
	10	0	0	3.4
	Avg:	0		

APPROXIMATE WEIGHT OF MATERIAL (as measured by Govmark): 16.7 oz/yd<sup>2</sup>

ACCEPTANCE CRITERIA:

Afterflame: 4.0 seconds maximum avg for length or width  
Afterglow: (see Note #2 below)  
Char Length: 6.0" maximum for any individual specimen

Notes:

1. An asterisk (\*) next to any char length measurements indicates that a part of the char length is melt away due to heat from the flame source and not from propagating flame. Therefore, the sample submitted meets the requirements of Title 19 - California Code of Regulations, Section 1237 and 1237.1 for materials weighing less than 4 oz/yd<sup>2</sup>.
2. Afterglow is required to be reported; however, it is not factored into the Acceptance Criteria.



The  
**Govmark**  
Organization, Inc.

96-D Allen Boulevard  
Farmingdale, New York 11735-5626 USA  
Tel. +1 (631) 293-8944 Fax +1 (631) 293-8956  
e-mail: info@govmark.com

Page 2

Received: 04/06/2009		Completed: 04/08/2009		Letter: A	rb	P.O.#:	Test Report #: 2-78069-0-
Client's Identification	UltraBlockout Banner Pro Double-Sided Blockout Banner Material For Two-Sided Printing.						
Tested For: <b>Jalme L. Giannantonio</b> Ultraflex Systems Inc. 1578 Sussex Tpk., Bldg. #4 Randolph, NJ 07869				Key Test: CA 1237 Sm			105
				Tel: 1-(973)-627-8608		Ext: 124	
				Fax: 1-(973)-627-8506			

CONCLUSION: Based on the above Results and Acceptance Criteria, the item tested:

☒ Complies;    ☐ Does not comply

REMARKS: None.

NOTE: In August 1993 the State Fire Marshal issued a proposed revision, which permitted a maximum average afterflame of 4.0 seconds. This proposed revision was honored by the subsequent State Fire Marshal until approximately February 2004, at which time the State Fire Marshal's office reverted to the unrevised rule of 2.0 seconds maximum average for exterior fabric.

In a conversation with the latest California State Fire Marshal on August 9, 2007, it was learned that the proposed 1993 revision is now back in effect. In addition to allowing 4 seconds Afterflame rather than 2 seconds, the proposed revision provides for testing of 10 specimens, rather than 6 specimens.

CERTIFICATION: I certify that the above results were obtained after testing specimens in accordance with the procedures and equipment specified by California Fire Marshal Title 19: Section 1237 (Proposed Revision 8/9/93).

*Heather E. Robertson*

AUTHORIZED SIGNATURE  
THE GOVMARK ORGANIZATION, INC. /mg

**MS. HEATHER ROBERTSON**

**MAY 01 2009**

(Page 2 of 2)



Received: 04/06/2009 Completed: 04/16/2009 Letter: A1 rb P.O.#: Test Report #: 2-78069-1-

Client's Identification UltraBlockout Banner Pro Double-Sided Blockout Banner Material For Two-Sided Printing.

Tested For: **Jaime L. Giannantonio**  
Ultraflex Systems Inc.  
1578 Sussex Tpk., Bldg. #4  
Randolph, NJ 07869

Key Test: CA 1237 Sm WL 105

Tel: 1-(973)-627-8608 Ext: 124  
Fax: 1-(973)-627-8506

PC: 1H /jd

TEST PERFORMED: California Fire Marshal Title 19: Section 1237 (Proposed Revision 8/9/93) Fire Resistance; Small Scale Test - EXTERIOR MATERIALS QUALIFICATION

RESULTS REPORTED: [ ] Initially  
[x] After 72 hours water leaching  
[ ] After 100 hours weathering

RESULTS:	Specimen #	Afterflame (seconds)	Afterglow (seconds)	Char Length (inches)
Warp:	1	0.0	0.0	4.1
	2	0.0	0.0	4.2
	3	0.0	0.0	3.4
	4	0.0	1.8	4.0
	5	0.0	1.0	4.0
	Avg:	0.0		
Fill:	6	0.0	0.0	4.0
	7	0.0	1.3	4.4
	8	1.3	0.0	3.2
	9	0.9	0.0	3.8
	10	0.0	0.0	4.1
	Avg:	0.4		

APPROXIMATE WEIGHT OF MATERIAL (as measured by Govmark): 16.7 oz/yd<sup>2</sup>

ACCEPTANCE CRITERIA:

Afterflame: 4.0 seconds maximum avg for length or width  
Afterglow: (see Note #2 below)  
Char Length: 6.0" maximum for any individual specimen

Notes:

1. An asterisk (\*) next to any char length measurements indicates that a part of the char length is melt away due to heat from the flame source and not from propagating flame. Therefore, the sample submitted meets the requirements of Title 19 - California Code of Regulations, Section 1237 and 1237.1 for materials weighing less than 4 oz/yd<sup>2</sup>.
2. Afterglow is required to be reported; however, it is not factored into the Acceptance Criteria.



Received: 04/06/2009	Completed: 04/16/2009	Letter: A1	rb	P.O.#:	Test Report #:	2-78069-1-
Client's Identification	UltraBlockout Banner Pro Double-Sided Blockout Banner Material For Two-Sided Printing.					
Tested For: <b>Jaime L. Giannantonio</b>			Key Test: CA 1237 Sm WL			105
Ultraflex Systems Inc.			Tel: 1-(973)-627-8608			Ext: 124
1578 Sussex Tpk., Bldg. #4			Fax: 1-(973)-627-8506			
Randolph, NJ 07869						

CONCLUSION: Based on the above Results and Acceptance Criteria, the item tested:

☒ Complies;    ☐ Does not comply

REMARKS: None.

NOTE: In August 1993 the State Fire Marshal issued a proposed revision, which permitted a maximum average afterflame of 4.0 seconds. This proposed revision was honored by the subsequent State Fire Marshal until approximately February 2004, at which time the State Fire Marshal's office reverted to the unrevised rule of 2.0 seconds maximum average for exterior fabric.

In a conversation with the latest California State Fire Marshal on August 9, 2007, it was learned that the proposed 1993 revision is now back in effect. In addition to allowing 4 seconds Afterflame rather than 2 seconds, the proposed revision provides for testing of 10 specimens, rather than 6 specimens.

CERTIFICATION: I certify that the above results were obtained after testing specimens in accordance with the procedures and equipment specified by California Fire Marshal Title 19: Section 1237 (Proposed Revision 8/9/93).

*Heather E. Robertson*

AUTHORIZED SIGNATURE

THE GOVMARK ORGANIZATION, INC.

**MS. HEATHER ROBERTSON**

**MAY 01 2009**

(Page 2 of 2)



Received: 04/06/2009 Completed: 04/27/2009 Letter: A2 rb P.O.#: Test Report #: 2-78069-2-

Client's Identification UltraBlockout Banner Pro Double-Sided Blockout Banner Material For Two-Sided Printing.

Tested For: **Jaime L. Giannantonio**

Key Test: CA 1237 Sm AW

105

Ultraflex Systems Inc.

1578 Sussex Tpk., Bldg. #4

Randolph, NJ 07869

Tel: 1-(973)-627-8608

Ext: 124

Fax: 1-(973)-627-8506

PC: 1H /jd

TEST PERFORMED: California Fire Marshal Title 19: Section 1237 (Proposed Revision 8/9/93) Fire Resistance; Small Scale Test - EXTERIOR MATERIALS QUALIFICATION

RESULTS REPORTED: [ ] Initially  
[ ] After 72 hours water leaching  
[x] After 100 hours weathering

RESULTS:	Specimen #	Afterflame (seconds)	Afterglow (seconds)	Char Length (inches)
Warp:	1	1.8	0	4.0
	2	1.5	0	3.7
	3	0.8	0	3.0
	4	0.0	0	4.3
	5	0.7	0	3.5
	Avg:	1.0		
Fill:	6	0.0	0	3.1
	7	1.4	0	3.7
	8	1.4	0	3.4
	9	0.0	0	2.9
	10	0.0	0	4.4
	Avg:	0.6		

APPROXIMATE WEIGHT OF MATERIAL (as measured by Govmark): 16.7 oz/yd<sup>2</sup>

ACCEPTANCE CRITERIA:

Afterflame: 4.0 seconds maximum avg for length or width

Afterglow: (see Note #2 below)

Char Length: 6.0" maximum for any individual specimen

Notes:

1. An asterisk (\*) next to any char length measurements indicates that a part of the char length is melt away due to heat from the flame source and not from propagating flame. Therefore, the sample submitted meets the requirements of Title 19 - California Code of Regulations, Section 1237 and 1237.1 for materials weighing less than 4 oz/yd<sup>2</sup>.

2. Afterglow is required to be reported; however, it is not factored into the Acceptance Criteria.

Received: 04/06/2009	Completed: 04/27/2009	Letter: A2	rb	P.O.#:	Test Report #:	2-78069-2-
----------------------	-----------------------	------------	----	--------	----------------	------------

Client's Identification	UltraBlockout Banner Pro Double-Sided Blockout Banner Material For Two-Sided Printing.
-------------------------	--

<b>Tested For: Jaime L. Giannantonio</b> Ultraflex Systems Inc. 1578 Sussex Tpk., Bldg. #4 Randolph, NJ 07869	<b>Key Test: CA 1237 Sm AW</b>  <b>Tel: 1-(973)-627-8608</b> <b>Fax: 1-(973)-627-8506</b>	<b>105</b>  <b>Ext: 124</b>
--	--	-----------------------------------

CONCLUSION: Based on the above Results and Acceptance Criteria, the item tested:

☒ Complies;    ☐ Does not comply

REMARKS: None.

NOTE: In August 1993 the State Fire Marshal issued a proposed revision, which permitted a maximum average afterflame of 4.0 seconds. This proposed revision was honored by the subsequent State Fire Marshal until approximately February 2004, at which time the State Fire Marshal's office reverted to the unrevised rule of 2.0 seconds maximum average for exterior fabric.

In a conversation with the latest California State Fire Marshal on August 9, 2007, it was learned that the proposed 1993 revision is now back in effect. In addition to allowing 4 seconds Afterflame rather than 2 seconds, the proposed revision provides for testing of 10 specimens, rather than 6 specimens.

CERTIFICATION: I certify that the above results were obtained after testing specimens in accordance with the procedures and equipment specified by California Fire Marshal Title 19: Section 1237 (Proposed Revision 8/9/93).

*Heather E. Robertson*

AUTHORIZED SIGNATURE

THE GOVMARK ORGANIZATION, INC. /jb/mj

**MS. HEATHER ROBERTSON**

**MAY 01 2009**

(Page 2 of 2)